



COMBINING HIGH RESOLUTION FORECASTS WITH DYNAMIC LINE RATING

PILOT SERVICE WITHIN DESTINATION EARTH (DESTINE) 374A


IRENE SCHICKER¹, ALEX DECKMYN², JORIS VAN DEN BERGH^{2,6}, WARRE VERLINDE³, PIET TERMONIA^{2,4},
VICTOR LE MAIRE⁵ AND TOMAS VAN OYEN³

¹GEOSPHERE AUSTRIA, VIENNA; ²ROYAL METEOROLOGICAL INSTITUTE BELGIUM; ³PROPHESSEA; ⁴GHENT UNIVERSITY; ⁵ELIA TRANSMISSION BELGIUM; UNIVERSITY OF ANTWERP⁶



Image Caption Udamendi geniet magnificus etv





Motivation

Why DLR Matters More Than Ever







Hectometric Resolution Modern meteorological forecast models at ~1 km and higher resolution and vertical high resolution enables nearly one grid point per transmission pylon — unlocking precise, location-specific DLR calculations.

Impact of Climate Change Rising temperatures and more frequent heat waves and possible changes in wind patterns, increase thermal stress on transmission lines already now, making weather-aware capacity management essential.

Renewables distribution in Austria High concentration of wind energy production in the east and storage capacities in the west require efficient grid capacity utilization to transport renewable electricity.

Dynamic Line Rating (DLR)

Impact of temperature and wind on overhead transmission line capacity



Interpretation

Static Rating: Based on conservative assumptions (high temperature, low wind). Protects the line but doesn't utilize full capacity.

Dynamic Line Rating: Uses real-time weather data for optimal line capacity utilization. Under favorable conditions (cool + windy), capacity can increase by 30-50%.

⚠ Critical during heat waves: High temperature + weak wind leads to: • Increased conductor resistance • Greater sag • Reduced transmission capacity (15-30% loss)

Based on: IEEE Std 738-2023 & Karimi et al. (2018), Renewable and Sustainable Energy Reviews



Why Dynamic Line Rating?


Static Rating – T

Conservative assumptions

- Wind speed: 0.6 m/s
- High ambient temperature
- Clear sky radiation

→ Underutilization of capacity

→ Limits renewable energy production



Fully dynamic 3: assigned weather station is representative for entire section/line

15-min values wind speed and ambient temperature multiplied by reduction/increase factor

Static with monthly values & of forecast values:

Conservative, constant wind speed (0.6 m/s), clear sky radiation, monthly/forecasted max temperature and clear sky conditions



Conductor Heat Balance and Weather – a sensible relationship

Wind speed cooling capacity dominates – but compound effects matter most

Parameter	Unfavourable	Favourable	Impact
Wind speed	< 2 m/s	> 5 m/s	DOMINANT – convective cooling
Temperature	> 30°C	< 20°C	Temperature gradient
Solar radiation	> 600 W/m ²	< 400 W/m ²	Direct heating
Precipitation	—	> 0.1 mm/h	Evaporative cooling (+20-50%)

Thresholds based on CIGRE Technical Brochures 207 and 601

Single parameters can be compensated if not too extreme.

The **combination** of unfavourable conditions = critical.

Example: 25°C is OK with 6 m/s wind, but critical with 1 m/s wind.



Can we detect such conditions ahead in time?

Can we predict DLR along the power line?

Can we predict ampacity with meteorological forecasts at heights above ground suitable for DLR?



From Detection to Hectometric: The Workflow

Smart triggering reduces computational cost while maintaining coverage

⚡ Computational Efficiency

Hectometric data is expensive:

- 1489×1489 grid points
- 15-minute temporal resolution
- Multiple vertical levels

Smart triggering = run only when & where needed



🌍 Full European Coverage

Continental screening ensures:

- No critical event missed
- Early warning (2-5 days)
- Multi-TSO coordination

"Always watching" without running everything everywhere

🎯 Actionable Intelligence

TSOs need specifics:

- Which segment is critical?
- What is the ampacity?
- When does it change?

Hectometric resolution answers these questions

Why This Matters



Multi-Scale NWP Integration

From continental early warning to local high-resolution analysis

Continental

ECMWF IFS ENS

~9 km, 51 members

Early warning and uncertainty (2-5 days)

Global DT (Optional)

DestinE Global

~4.4 km

European screening

Regional (Optional)

AROME/ALARO

1 - 2.5 km


Mesoscale features

Hectometric

DestinE Extremes

~500 m

Bottleneck resolution



Compound Event Detection Algorithm

Categorical scoring system inspired by IPCC likelihood scales

Score	Category	Definition	Operational Action
≤ -2	Very Unfavorable	Multiple critical thresholds exceeded	Capacity reduction required
-1	Unfavorable	Single critical threshold exceeded	Exercise caution
0	Neutral	All parameters within normal range	Static rating applies
+1	Favorable	Single favorable threshold met	Moderate capacity increase
≥ +2	Very Favorable	Multiple favorable conditions	Significant capacity increase

Processing Modes:

Deterministic (AROME, ALARO)

- Lateral sampling: ±1 grid points
- Creates "ensemble-like" spatial uncertainty
- Reduces sensitivity to single grid-point values


Probabilistic (ECMWF ENS)

- K-means clustering (K=5-7 scenarios)
- Preserves forecast uncertainty
- Probability: $P(\text{ampacity} > \text{baseline}) = \sum_i w_i \times I(I_{\text{max},i} > I_0)$




Continental-Scale DLR Detection

**EXTENDED - DLR Severity (5-Category)
T+36h**



BASE index (Wind + Temperature) from ECMWF IFS at T+0h

**EXTENDED - DLR Condition Probability Index
T+36h**





Thermal Model Implementation

CIGRE & IEEE 738 for quantitative ampacity calculation

CIGRE TB 207/601

European standard – typically more optimistic

IEEE 738-2012

American standard – more conservative

CIGRE Heat Balance: $I^2R(T_c) + q_{solar} = q_{convective} + q_{radiative}$

Line	Conductor	Diameter	Baseline	Max Temp
APG 220 kV (Tyrol)	ACSR Drake	28.1 mm	1200 A	80°C
E-Netze Steiermark 110 kV	ACSR 240/40	21.8 mm	600 A	80°C
Elia 150 kV (Belgium)	Generic ACSR	25.0 mm	800 A	80°C


Implementation Features:

- **Temperature-dependent resistance:** $R(T) = R_{20}[1 + \alpha(T-20)]$
- **Forced convection:** $Nu = f(Re)$ with wind angle correction
- **Air density correction:** ~10% per 1000m elevation
- **Iterative solution:** Convergence tolerance 0.1°C



Spatial Bottleneck Identification

The weakest link determines corridor capacity



Grid-point DLR detection (1489x1489 points) with transmission line overlay

Hectometric Resolution Enables:

- 79 individual pylon-to-pylon spans
- Meteorological gradients resolved
- Temperature: 12°C gradient along 25 km!

Line vs Domain comparison:

- Line: 89% favorable spans
- Domain average: 40% favorable

Operational Value:



- Identify exactly where to install weather stations
- Target monitoring at critical segments only
- Inform infrastructure investment decisions with spatial precision



Belgian Case Study: Elia Quaregnon-Trivieres 150 kV

Conditions: T: 10-22°C | Wind: 4-6 m/s | DLR Score: +2 to +3



DestinE Extremes: ~500 m resolution | 25 km corridor | 79 spans | 48h forecast



Left: CIGRE ampacity per segment [A] | Right: Spatial DLR conditions with wind vectors






Austrian Case Study: 110 kV line








CIGRE Analysis: Pongau - Weissenbach



Full line segment


Dirunal patterns
Importance of different heights above ground of forecast data
Mean increase: +25-35% vs 600 A static





Web API & Service Access

Accessible through the DestinE Platform



Publicly available through the DestinE Platform: destination-earth.eu

Data Access via Polytope API (ECMWF)

User Capabilities

- **Spatial subsetting:** Extract along transmission line geometry
- **Vertical profiles:** Multi-level extraction (2m, 10m, 50m, 60m, 80m, 100m AGL)
- **Temporal windowing:** 0-48h for day-ahead TSO planning

3. Spatial analysis – Per-segment conditions
4. Quantitative output – Ampacity in Amperes



Conclusions & Outlook

Key Achievements

- ✓ Multi-scale NWP integration
(9 km → 500 m)
- ✓ Compound event detection

Future Development

- Probabilistic forecasting with ensemble NWP models
- ML enhancement of detection algorithms
- Extension to additional European TSOs and DSOs

Take-Home Message

Combining DestinE high-resolution forecasts with thermal models enables spatially-resolved DLR forecasting – identifying exactly where and when transmission capacity can be safely increased.

Thank you! – Questions?

✓ 48-hour forecasts

for day-ahead planning